

## REPORT OF DRINKING WATER ANALYSIS

EPA Accredited Lab ID # : NO.093

Sampling Company : East Tender Environmental and Safety Technology CO.,LTD.

Laboratory Add. : No.99, Ligong 2nd Rd., Wujie Township, Yilan County 268, Taiwan (R.O.C.)

Sampling Add. : No. An Nong Xincun 1, Ln. 365, Sec. 3, Sanxing Rd., Sanxing Township, Yilan County 266, Taiwan (R.O.C.)

TEL : (03)9900999

Purpose : For Testing

FAX : (03)9900998

Sample Collection Date : 2025/6/5 10:33

Name of Applicant : Yilan Prison, Agency of Corrections, Ministry of Justice

Lab Receipt Date : 2025/6/5 16:55

Report Completed Date : 2025/6/24

Industry Classifications : \*

Items	Lab Sample No.		D1140605-2-1			Analysis Method	Remarks
	Dakanchang						
	Unit	Result Value					
Coliform group	CFU/100mL	<1				NIEA E230.55B	
Colony forming	CFU/mL	<1				NIEA E204.55B	
Free available residual chlorine	mg/L	0.27				NIEA W408.51A	
Blank below							

## Announcement :

All the above items are analyzed by credit laboratory. I certify that information submitted is, to the best of my knowledge and belief, true, accurate, and complete.

Company : East Tender Environmental and Safety Technology CO.,LTD.

President of ETEST : Zheng-Liang Lin

Authorized signature :



報告專用章  
東典環安科技(股)公司  
負責人：林正亮  
檢驗室主管：許智明

## REPORT OF DRINKING WATER ANALYSIS

EPA Accredited Lab ID # : NO.093

Sampling Company : East Tender Environmental and Safety Technology CO.,LTD.

Laboratory Add. : No.99, Ligong 2nd Rd., Wujie Township, Yilan County 268, Taiwan (R.O.C.)

Sampling Add. : No. An Nong Xincun 1, Ln. 365, Sec. 3, Sanxing Rd., Sanxing Township, Yilan County 266, Taiwan (R.O.C.)

TEL : (03)9900999

Purpose : For Testing

FAX : (03)9900998

Sample Collection Date : 2025/6/5 10:25

Name of Applicant : Yilan Prison, Agency of Corrections, Ministry of Justice

Lab Receipt Date : 2025/6/5 16:55

Report Completed Date : 2025/6/24

Industry Classifications : \*

Items	Lab Sample No.		D1140605-2-2			Analysis Method	Remarks
		We11 1					
	Unit	Result Value					
NO <sub>3</sub> -N	mg/L	1.11				NIEA W419.51A	MDL=0.00015
As	mg/L	N.D.				NIEA W434.54B	
Blank below							



Announcement :

All the above items are analyzed by credit EPA laboratory. I certify that information submitted is, to the best of my knowledge and belief, true, accurate, and complete.

Company : East Tender Environmental and Safety Technology CO.,LTD.

President of ETEST : Zheng-Liang Lin

Authorized signature :



## REPORT OF DRINKING WATER ANALYSIS

EPA Accredited Lab ID # : NO.093

Sampling Company : East Tender Environmental and Safety Technology CO.,LTD.

Laboratory Add. : No.99, Ligong 2nd Rd., Wujie Township, Yilan County 268, Taiwan (R.O.C.)

Sampling Add. : No. An Nong Xincun 1, Ln. 365, Sec. 3, Sanxing Rd., Sanxing Township, Yilan County 266, Taiwan (R.O.C.)

TEL : (03)9900999

Purpose : For Testing

FAX : (03)9900998

Sample Collection Date : 2025/6/5 10:27

Name of Applicant : Yilan Prison, Agency of Corrections, Ministry of Justice

Lab Receipt Date : 2025/6/5 16:55

Report Completed Date : 2025/6/24

Industry Classifications : \*

Items	Lab Sample No.		D1140605-2-3			Analysis Method	Remarks
		Well 2					
	Unit	Result Value					
NO3-N	mg/L	1.22				NIEA W419.51A	MDL=0.00015
As	mg/L	N.D.				NIEA W434.54B	
Blank below							

Announcement :

All the above items are analyzed by credit EPA laboratory. I certify that information submitted is, to the best of my knowledge and belief, true, accurate, and complete.

Company : East Tender Environmental and Safety Technology CO.,LTD.

President of ETEST : Zheng-Liang Lin

Authorized signature :



報告專用章  
東典環安科技(股)公司  
負責人:林正亮  
檢驗室主管:許智明

## REPORT OF DRINKING WATER ANALYSIS

EPA Accredited Lab ID # : NO.093

Sampling Company : East Tender Environmental and Safety Technology CO.,LTD.

Laboratory Add. : No.99, Ligong 2nd Rd., Wujie Township, Yilan County 268, Taiwan (R.O.C.)

Sampling Add. : No. An Nong Xincun 1, Ln. 365, Sec. 3, Sanxing Rd., Sanxing Township, Yilan County 266, Taiwan (R.O.C.)

TEL : (03)9900999

Purpose : For Testing

FAX : (03)9900998

Sample Collection Date : 2025/6/5 10:29

Name of Applicant : Yilan Prison, Agency of Corrections, Ministry of Justice

Lab Receipt Date : 2025/6/5 16:55

Report Completed Date : 2025/6/24

Industry Classifications : \*

Lab Sample No.		D1140605-2-4			Analysis Method	Remarks
		We11 3				
Items	Unit	Result Value				
NO3-N	mg/L	1.10			NIEA W419.51A	
As	mg/L	N.D.			NIEA W434.54B	MDL=0.00015
Blank below						

Announcement :

All the above items are analyzed by credit EPA laboratory. I certify that information submitted is, to the best of my knowledge and belief, true, accurate, and complete.

Company : East Tender Environmental and Safety Technology CO.,LTD.

President of ETEST : Zheng-Liang Lin

Authorized signature :